

# Engineered Solutions

Technical Considerations for  
Centrifugal Compressor  
Optimization and  
Electrification

TNChE 2026  
Swaroop Das



EBARA ELLIOTT ENERGY



# Mission

Provide customer-centric solutions in the quickest and most efficient manner possible. Provide safe working environments that encourage challenge and change. Act and achieve as one team.

# vision


Be the Best Solution Provider in the energy sector by providing premier equipment and service, while actively leading sustainability efforts worldwide.

# Summary

1. What is a Centrifugal Compressor
2. Concept of re-rating / drop-in
3. Compressor design for electrical motor drives (EMD)
4. Case studies and real world applications
  - Customer A
  - Customer B
  - CAPEX and ROI: Modification vs Re-rate
5. Conclusions: Lessons learnt and best practices

# What is a centrifugal compressor and applications?

“Inline centrifugal compressors can be described as a combination of one or more centrifugal compressor stages operating about a common axis. Each stage is comprised of rotating impellers that impart kinetic energy into the gas that is then converted to a rise in static pressure as the gas decelerates.”







# Concept of re-rating

Re-rating a centrifugal compressor requires changing the aero-path. At its core, re-rating involves recalibrating a compressor's design and operational parameters to optimize its performance under new or current working conditions. This means that diaphragms (diffusers) and rotor (impellers and shaft) will be newly supplied with modern aero design.

- Achieve new process parameters or increase efficiency within existing casings
- Minimal changes to foundations, piping and other connections




# Concept of drop-in replacements



Site Scan

Develop Model



- Increase in Capacity of 30%
- Upgrade to Dry Gas Seals & modern aero
- Match process nozzles, auxiliary connections and existing pedestals




Custom Casing

Overlay casing

# Concept of re-rating

Why re-rating is important: Is the compressor operating at design?






# Concept of re-rating




60 €/tonCO2  
68 €/MWh  
95% availability

| POWER AND POTENTIAL POWER SAVINGS (kW) |            |            |             |             | POTENTIAL TOTAL SAVINGS PER YEAR (€) |             |             |             |
|----------------------------------------|------------|------------|-------------|-------------|--------------------------------------|-------------|-------------|-------------|
| Power (kW)                             | 1950-1960s | 1960-1970s | 1980s-1990s | 1990s-Today | 1950-1960s                           | 1960-1970s  | 1980s-1990s | 1990s-Today |
| 1000                                   | 200        | 70         | 50          | 30          | € 183.983                            | € 64.394    | € 45.996    | € 27.597    |
| 3000                                   | 600        | 210        | 150         | 90          | € 551.948                            | € 193.182   | € 137.987   | € 82.792    |
| 5000                                   | 1000       | 350        | 250         | 150         | € 919.914                            | € 321.970   | € 229.978   | € 137.987   |
| 7000                                   | 1400       | 490        | 350         | 210         | € 1.287.879                          | € 450.758   | € 321.970   | € 193.182   |
| 9000                                   | 1800       | 630        | 450         | 270         | € 1.655.845                          | € 579.546   | € 413.961   | € 248.377   |
| 11000                                  | 2200       | 770        | 550         | 330         | € 2.023.811                          | € 708.334   | € 505.953   | € 303.572   |
| 20000                                  | 4000       | 1400       | 1000        | 600         | € 3.679.656                          | € 1.287.879 | € 919.914   | € 551.948   |
| 30000                                  | 6000       | 2100       | 1500        | 900         | € 5.519.483                          | € 1.931.819 | € 1.379.871 | € 827.922   |
| 40000                                  | 8000       | 2800       | 2000        | 1200        | € 7.359.311                          | € 2.575.759 | € 1.839.828 | € 1.103.897 |





# Turbine to Motor Conversion



## “Drivers” of change

- Electric motor, drivers – Latest Trends due to clean energy initiatives
- High Steam Cost
- High Carbon Footprint using Steam Turbines
- Potential Lower maintenance interval times and higher efficiency

## Considerations


- Impact of Driver Selection on Compressor Design
  - Shaft End Sizing
  - Starting torque requirements
  - Settle-out pressure requirements
  - Short Circuit faults and Transient torsional requirements
  - Coast down calculations
- Available Footprint and changes required
- Strings with Gearbox

# Turbine to Motor Conversion

42 MW Steam turbine driven compressor string dimensions (\*steam condenser / generation not shown\*):

66.5ft(L) X 14.5ft(W) X 13.5ft(H)


Total String Weight: 710,510 lbs



42 MW electric motor driven compressor string dimensions (\*VSD not shown\*):

67ft(L) X 14.5ft(W) X 16.9ft(H)

Total String Weight: 753,500 lbs






# Turbine to Motor Conversion

## Shaft End Sizing – How will the new torque affect shaft end size?

- What is the minimum upgrade scope when shaft end size requires increase?
- Can we upgrade parts for increase reliability?
- How does that compare to re-rate?





Shaft end size 6.5 to 9in

***New shaft required – requires stacking & unstacking of main rotor and spare rotor***

# Turbine to Motor Conversion

## Shaft End Sizing – How will the new torque affect shaft end size?

- shaft end sizing criteria is based on ANSI/AGMA 6001 standard. This includes consideration of high cycle fatigue for continuous operation and low cycle fatigue for start-up and transient events.
- Short circuit moment
- Significant increase in shaft end sizing for motor drives
- Shaft end size can affects bearing sizes, overhung weight, rotor dynamic analysis.



|                                                           | Shaft end size (in), Hydraulic fit |            |              |
|-----------------------------------------------------------|------------------------------------|------------|--------------|
| Driver Rating 42MW                                        | Compressor2                        |            | Compressor 1 |
| String Configuration                                      | Drive                              | Drive Thru | Drive        |
| Steam Turbine+<br>Compressor2+Compressor1                 | 6.5                                | 5.5        | 5.5          |
| Synch. Motor w/VFD (LCI)<br>+Gear+Compressor2+Compressor1 | 9                                  | 8.5        | 8.5          |
| Synch. Motor w/VFD (VSI)<br>+Gear+Compressor2+Compressor1 | 9                                  | 8.5        | 8.5          |
| Synch. Motor (DOL)<br>Gear+Compressor2+Compressor1        | 10.5                               | 10.5       | 10.5         |

Driver configuration vs. Shaft end sizing



# CAPEX vs OPEX Trade-offs

| Configuration                                           | CapEx (Initial Cost)                                                                 | OpEx: Footprint & Layout                                                                             | OpEx: Cooling Loads                                                                                      | OpEx: Maintenance                                                                                   |
|---------------------------------------------------------|--------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|
| 1. Standard Motor + VFD + Gearbox                       | <b>Baseline</b><br>Standard, off-the-shelf motor and gear components.                | <b>Large</b><br>Requires long mechanical skid AND a large, climate-controlled E-house.               | <b>Split</b><br>High electrical (VFD HVAC) + Moderate mechanical (Gearbox oil).                          | <b>Moderate</b><br>Routine gearbox oil changes, standard motor bearings, VFD upkeep.                |
| 2. Fixed-Speed Motor + Fluid Coupling / Planetary Gears | <b>High</b><br>Highly specialized, massive mechanical power-split drive.             | <b>Heavy Mechanical</b><br>Massive mechanical skid, but minimal electrical room space required.      | <b>Massive Mechanical</b><br>Huge oil coolers required to reject 400–700+ kW of thermal fluid slip heat. | <b>Moderate-High</b><br>Complex oil system and fluid coupling maintenance, but extremely long MTBF. |
| 3. High-Speed Motor + VFD (Direct Drive)                | <b>Highest</b><br>Engineered-to-order motor, magnetic bearings, and specialized VFD. | <b>Compact Mechanical</b><br>Shortest physical skid, but still requires a large E-house for the VFD. | <b>Mostly Electrical</b><br>High electrical (VFD HVAC), but zero mechanical lube oil cooling needed.     | <b>Lowest</b><br>No gearbox, no lube oil console. Only specialized electrical/bearing checks.       |



A photograph of an industrial setting where workers are handling a large, heavy-duty mechanical component, possibly a turbine or pump part. The workers are wearing safety gear like hard hats and gloves. The scene is overlaid with a large red semi-circle on the right side and a white circle in the bottom left corner. The background shows a complex industrial structure with various pipes and beams.

# CASE STUDIES









## Case Study – Customer A

**Scope:** March 2023 – Electrification study for 3 Compressors to evaluate minimum change requirements and re-rate evaluation.


Jan 2024 – PO to electrify driver of 2 compressors.






# Case Study – Customer A

**Scope:** March 2023 – Electrification study for 3 Compressors to evaluate minimum change requirements and re-rate evaluation.  
Jan 2024 – PO to electrify driver of 2 compressors.



| K401        | Existing Rotor Performance | Rerated Rotor Performance | Estimated Power Savings |      |
|-------------|----------------------------|---------------------------|-------------------------|------|
| Speed (rpm) | 3707                       | 3742                      |                         |      |
| Power (kW)  | 20395                      | 18560                     | 1835                    | 9.0% |

Table 1: K401 Rerated Power Summary




| K404        | Existing Rotor Performance | Rerated Rotor Performance | Estimated Power Savings |      |
|-------------|----------------------------|---------------------------|-------------------------|------|
| Speed (rpm) | 5214                       | 5298                      |                         |      |
| Power (kW)  | 7310                       | 7190                      | 120                     | 1.6% |

Table 3: K404 Rerated Power Summary

# Case Study – Customer A

**Scope:** K401 – with re-rate for 1.8MW power saving




- Full gut re-rate
- Spare rotor
- Keep same Thrust bearings
- Keep same end-walls
- Keep casing seals
- New journal bearings
- New coupling/guard
- Spare coupling
- Full Train torsional analysis
- Lube oil modifications.



# Case Study – Customer A


Scope: K404 – Without re-rate



- New coupling + guard
- Spare coupling
- Full Train torsional analysis
- Lube oil modifications
- Baseplate engineering & modal analysis

# Case Study – Customer A


## K404: Baseplate challenges



- No dimensional dwgs
- Reverse Engineer the existing baseplate
- where to cut?
- New motor-Baseplate design
- Location of anchor bolts?
- Rebar of tabletop?



# Case Study – Customer A

## K404: Baseplate challenges



**Objective:** The objective is to perform Static structural Analysis, Modal Analysis & Harmonic Analysis on Base Plate Assembly


**Analysis Approach**





# Case Study – Customer B

**Scope:** October 2023 Electrification study to evaluate minimum change requirements, release compressor startup-curves, Motor Selection and re-rate evaluation.  
August 2024 – PO to electrify the compressor




| Compressor  | Existing Aero | Re-Rated Aero | Estimated power savings |
|-------------|---------------|---------------|-------------------------|
| Power (kW)  | 19'109        | 17'777        | 7%                      |
| Speed (rpm) | 3'840         | ~3'840        |                         |

# Case Study – Customer B

## Scope:


- New Shaft / Thrust Disk
- Rotor Re-shafting services
- Complete Spare rotor
- New end cover/ end seal
- New Journal Bearing assembly
- New GB and GB/Motor Baseplate (and FEA)
- New low speed & high speed couplings and guards
- Full Train torsional analysis
- Lube oil modifications



# CAPEX and ROI: Modification vs Re-rate

60 €/tonCO2  
68 €/MWh  
95% availability

|            | CAPEX        |         | POWER         | ROI |
|------------|--------------|---------|---------------|-----|
|            | MODIFICATION | RE-RATE | SAVINGS in kW |     |
| CUSTOMER A | 1            | 2.87    | 1835          | 1.5 |
| CUSTOMER B | 1            | 2.95    | 1332          | 1.7 |



Customer B Layout

Customer A: K401 opted for Re-rate  
Customer B: Did not opt for Re-rate

ROI/CAPEX excludes offset of purchasing smaller Motor/VFD

ROI/CAPEX would most likely be smaller if it did.

ROI of Customer A and Customer B are very similar but they opted by different approaches. Reasons?

- Complexity of Steam Balance for Customer B?
- Power & CO2 Savings not enough?
- Source of electricity?
- Not enough budget?



# Conclusions: Lessons learnt and best practices

- Engineering studies to identify minimum scope of supply are crucial.
  - Serve as baseline analysis of the feasibility of electrification: Evaluation of scenarios and ensures compatibility.
  - Identify all the necessary minimum scope – avoid overlooking critical aspects
  - Compare minimum scope with extended re-rate scope (CAPEX/OPEX/ROI benefits)
  - Address complexities of electrification of large centrifugal compressors
- Compressor original design point does not match current operating conditions
- **Compressor Re-Rating can bring attractive ROIs and maximizing efficiency and sustainability by furthering reducing CO2 emissions.**
- Ideal Project set up with Compressor OEM or expert having responsibility for Motor / Drive supply.

# Thank You

Swaroop Das– ES Regional Sales Manager  
South East Asia, Australia, India



EBARA ELLIOTT ENERGY